



시험성적서

Provided sample

Client Name : HYUNDAI Wacortec Co., Ltd. Certificate No. : 일반-180107
Address : A-301, Hagye Technotown, 10, Nowon-ro 15-gil, Nowon-gu, Seoul, Korea Date of Enforcement : Feb. 18, 2018
Test Sample : UF filter Use of Report : Presentation
Date of Receipt : Feb. 6, 2018 Date of Test : Feb. 6, 2018 ~ Feb. 18, 2018
Testing Environment : Temperature : (35 ± 0.5) °C, Relative Humidity : 45 % R.H.
Test method used : Pour Plate Method

Test Results

Items	Unit	Result			Remark
		The synthesis water	The passed water	Removal Rate (%)	
<i>E. coli</i>	CFU/mL	1 500	Not Detected	100	-
<i>Staphylococcus aureus</i>	CFU/mL	1 900	Not Detected	100	-
<i>Salmonella</i>	CFU/mL	1 100	Not Detected	100	-
<i>Pseudomonas aeruginosa</i>	CFU/mL	1 500	Not Detected	100	-
<i>Shigella</i>	CFU/mL	2 000	Not Detected	100	-

※ Test condition (suggested by client)
- 100 L of the synthetic water ($\pm 10^3$ CFU/mL) passed through the sample and was analyzed

Notice 1. The results shown in this test report refer only to the offered sample by client.
2. The test report cannot be used for the purpose of litigation or advertising, and shouldn't be republished without document approval.

Received by

Seo Hyunho

Tested by

Beck Inkyu

Technical Manage

Song Minhyoung

Korea Environment & Water Works Institute



1 / 1 The End.